

Radon Testing Education 2017-18

As per the Radon Management Guidelines for Yukon government.

Measurements are Becquerels per cubic metre Bq/m ³ Measurements below 200 Bq/m ³ are within Health Canada guidelines.			
Facility	Highest Reading	Lowest Reading	Post Mitigation
Chief Zzeh Gittlit	41	22	N/A
Christ the King	248	63	
Del Van Gorder	122	56	N/A
Ecole Emilie-Tremblay	81	26	N/A
Elijah Smith	96	33	N/A
Eliza Van Bibber	204	78	
F.H. Collins	48	22	N/A
Gadzoosdaa Residence	52	15	N/A
Ghuch Tla Community	137	67	N/A
Golden Horn	67	22	N/A
Grey Mountain	74	52	N/A
Hidden Valley	63	26	N/A
Holy Family	204	78	
Individual Learning Centre	56	26	N/A
J.V. Clark	126	56	N/A
Jack Hulland	107	30	N/A
Johnson Elementary	107	52	N/A
Kluane Lake	92	67	N/A
Education – 1000 Lewes Blvd	44	15	N/A
Nelna Bessie John	74	15	N/A

Facility	Highest Reading	Lowest Reading	Post Mitigation
Porter Creek	67	26	N/A
Robert Service	74	33	N/A
Ross River	152	74	N/A
Selkirk	100	37	N/A
St. Elias Community	111	59	N/A
Takhini	81	30	N/A
Tantalus School - Carmacks	85	44	N/A
Teen Parent Centre	230	230	
Teslin	122	44	N/A
Vanier	163	26	N/A
Watson Lake Secondary	74	41	N/A
Whitehorse Elementary	96	30	N/A
Wood Street Centre	141	41	N/A
Mitigation requirements:			
<ul style="list-style-type: none"> • Between 200 and 600 Bq/m³ within 2 years • Over 600 Bq/m³ within 1 year 			