

Radon Testing Environment 2017-18

As per the Radon Management Guidelines for
Yukon government.

Measurements are Becquerels per cubic metre Bq/m ³ Measurements below 200 Bq/m ³ are within Health Canada guidelines.			
Facility	Highest Reading	Lowest Reading	Post Mitigation
10 Burns Road	259	15	
Mitigation requirements: <ul style="list-style-type: none">• Between 200 and 600 Bq/m³ within 2 years• Over 600 Bq/m³ within 1 year			