

Radon Testing Highways & Public Works 2017-18

As per the Radon Management Guidelines for Yukon government.

Measurements are Becquerels per cubic metre Bq/m ³ Measurements below 200 Bq/m ³ are within Health Canada guidelines.			
Facility	Highest Reading	Lowest Reading	Post Mitigation
9010 Quartz Road – second floor	<15	<15	N/A
113 Industrial Road, Paint Shop	30	26	N/A
Main Administration Building – ICT offices	26	<15	N/A
Canyon Mountain Building	37	18	N/A
Dawson FMRS Office	30	26	N/A
Haines Junction FMRS Office	33	26	N/A
Watson Lake FMRS Office	92	85	N/A
Mayo FMRS Office	<15	<15	N/A
Mitigation requirements: <ul style="list-style-type: none"> • Between 200 and 600 Bq/m³ within 2 years • Over 600 Bq/m³ within 1 year 			