

Radon Testing Women's Directorate 2017-18

As per the Radon Management Guidelines for Yukon government.

Measurements are Becquerels per cubic metre Bq/m ³ Measurements below 200 Bq/m ³ are within Health Canada guidelines.			
Facility	Highest Reading	Lowest Reading	Post Mitigation
#1 – 404 Hanson Street	88	53	N/A
Mitigation requirements: <ul style="list-style-type: none">• Between 200 and 600 Bq/m³ within 2 years• Over 600 Bq/m³ within 1 year			